



PURCHASING DEPARTMENT

COLE COUNTY COMMISSION

311 East High Street, Room 200 | Jefferson City, MO 65101
Tel 573-634-9168 | Fax 573-634-8031
jprenger@colecounty.org

To: All Interested Parties
From: Jennifer Prenger, Cole County Purchasing Agent
Date: August 16, 2018
Re: Addendum One to Cole County Bid No. 2018-32: Health Department Improvements- Doorway and Shower Installation & Window Replacement

The following information hereby becomes part of the above-referenced Request for Bid and shall be fully considered in the preparation of your response.

1. Shower is to be standard (~60" x 35" x 70") fiberglass with seat on right hand side. Glass door for shower must be included and installed as well.
2. Replacement windows do not need to be operable.
3. Replacement windows to be one panel/one row, reflective, two-pane, dark bronze frame, thermal material.
4. Replacement windows are to have sheet rock return inside.

The bid receipt date and time HAVE NOT BEEN CHANGED; submissions will be received until Thursday, August 23 at 3:30 p.m. The deadline for questions is Thursday, August 16, 2018.

I/We have received Addendum Number One to Bid No. 2018-32 and have fully considered the information provided in preparing a response.

Name of Company

Agent and Title

Authorized Signature