

ADDENDUM NO. 2
April 24, 2017

TO: PLANS AND SPECIFICATIONS FOR

RANDALL DRIVE NEIGHBORHOOD IMPROVEMENT DISTRICT PROJECT
PROJECT NO. 2016-001-1

Bidders are hereby informed that the construction plans and/or specifications are modified as follows:

Clarification/Substitution

The 4'x2' area inlet shall be constructed as a grated top and will not have open sides. It shall be constructed according to drawing 44.03 in the City of Jefferson Standard Details. A 4'x4' grated inlet may be substituted at the contractor's preference. There will be no adjustment in quantities or pay items related to any substitution.

BY THE ORDER OF:

Eric Landwehr, P.E., County Engineer
Cole County Department of Public Works
April 24, 2017