

**ADDENDUM NO. 3
October 18, 2017**

TO: PLANS AND SPECIFICATIONS FOR

**THE CROSSROADS, SOUTHTOWN ESTATES AND RUSTIC OAKS SUBDIVISIONS
STORMWATER AND STREET IMPROVEMENTS
PROJECT NO. 2015-201-1**

Bidders are hereby informed that the construction plans and/or specifications are modified as follows:

REINFORCING FIBERS FOR ASPHALT INFORMATION

A special asphalt mix design for the fiber reinforced asphalt will not be required. The submitted BP-1 mix design will be used and the proper quantity of reinforcing fibers will be determined by the manufacturer.

EXISTING PAVEMENT INFORMATION

Attached are asphalt pavement cores taken to determine existing pavement thickness at the locations taken. This is for information only and the pavement shall not be considered to be a consistent thickness throughout the project.

BY THE ORDER OF:

Eric Landwehr, P.E., County Engineer
Cole County Department of Public Works
October 18, 2017