



PURCHASING DEPARTMENT

COLE COUNTY COMMISSION

311 East High Street, Room 200 | Jefferson City, MO 65101
Tel 573-634-9168 | Fax 573-634-8031
jbryant@colecourt.org

To: All Interested Parties
From: Jessica Bryant, Cole County Purchasing Agent
Date: January 30, 2025
Re: Addendum Two to Cole County Bid No. 2025-03 Exterior Repairs
Cole County Health Department

The following information hereby becomes part of the above-referenced Request for Bid and shall be fully considered in the preparation of your response.

1. Can the loose siding be face nailed?
 - It needs to be stainless steel nails with ring shanks.

The bid receipt date and time HAVE NOT CHANGED; submissions will be received until Thursday, February 6, 2025 at 3:00 p.m.

I/We have received Addendum Number Two to Bid No. 2025-03 and have fully considered the information provided in preparing a response.

Name of Company

Agent and Title

Authorized Signature